



CEN/TC 127/WG 8  
CEN/TC 127/WG 8 - Fire Safety Engineering  
Email of secretary:  
Secretariat:

**WG8 N0047 UNIZA WI proposal Delft Part of UNIZA FIREFF project**

Document type: Other committee document

Date of document: 2015-03-23

Expected action: INFO

Background:

Committee URL: <http://cen.iso.org/livelink/livelink/open/centc127wg8>



**Department of Fire Engineering**

**Faculty of Security Engineering**

**University of Zilina**



# **WI Proposal:**

# **Economic assessment of fire protection measures**

**Ing. Vladimír MOZER, PhD.**

**TC 127 / WG 8 FSE – Delft meeting**

# Objective and introduction



The aim of the proposed WI is to provide means of objective assessment of fire safety design economic implications.

What is the highest level of safety which can be achieved at a given level of costs.

Especially useful when multiple design alternatives are considered – avoid „cutting corners“ by spending funds efficiently.

Combination of fire safety engineering output – extent of fire at given level of fire protection (costs) vs extent of damage and threat caused by the fire.

# Project background



**Long-time topic of interest for all stakeholders.**


**Numerous studies and publications (The value of fire protection in buildings, Economics of fire protection, etc.)**

**UNIZA currently working on this project under a national grant scheme funding.**

**Approach – Keep it simple and compatible with existing fire engineering tools.**

**Addition of a set of economic assessment tools on top of what is already there, i.e. no reinventing of the wheel.**

# Model framework description



# Example of application – property protection



**Probability of fire starting (ignition):**


***Industrial* – 0,096**

***Office* – 0,052**

***Shop* – 0,132**

**From PD 7974-7**

## Event tree analysis diagram



**values in brackets denote Unsprinklered scenario**

## Individual outcome probabilities

Fire scenario	Extent of damage	Outcome frequency	
		Sprinklered	Unsprinklered
Confined to 1 <sup>st</sup> item $E_1$	max. 5m <sup>2</sup>	0,790	0,220
Confined to contents $E_2$	50% of compartment	0,120	0,226
Confined to compartment of origin $E_3$	100% of compartment	0,068	0,415
Spread beyond compartment of origin $E_4$	2x compartment area	0,023	0,139



# Example of application – property protection

Occupancy	Fire starting		E1		E2		E3		E4	
	P	O	P	O	P	O	P	O	P	O
<i><b>Sprinklered</b></i>										
Industrial	$9,6 \cdot 10^{-2}$	10	$7,5 \cdot 10^{-2}$	13	$1,1 \cdot 10^{-2}$	87	$6,5 \cdot 10^{-3}$	155	$2,2 \cdot 10^{-3}$	464
Office	$5,5 \cdot 10^{-2}$	18	$4,4 \cdot 10^{-2}$	23	$6,6 \cdot 10^{-3}$	151	$3,7 \cdot 10^{-3}$	268	$1,2 \cdot 10^{-3}$	803
Shop	$1,3 \cdot 10^{-1}$	8	$1,0 \cdot 10^{-1}$	10	$1,6 \cdot 10^{-2}$	63	$8,9 \cdot 10^{-3}$	112	$3,0 \cdot 10^{-3}$	336
<i><b>Unsprinklered</b></i>										
Industrial	$9,5 \cdot 10^{-2}$	10	$2,1 \cdot 10^{-2}$	48	$2,2 \cdot 10^{-2}$	46	$4,0 \cdot 10^{-2}$	25	$1,3 \cdot 10^{-2}$	76
Office	$5,5 \cdot 10^{-2}$	18	$1,2 \cdot 10^{-2}$	82	$1,2 \cdot 10^{-2}$	80	$2,3 \cdot 10^{-2}$	44	$7,6 \cdot 10^{-3}$	131
Shop	$1,3 \cdot 10^{-1}$	8	$2,9 \cdot 10^{-2}$	34	$3,0 \cdot 10^{-2}$	33	$5,5 \cdot 10^{-2}$	18	$1,8 \cdot 10^{-2}$	55

## Extent of damage

Fire scenario	Extent of damage
Confined to 1 <sup>st</sup> item $E_1$	max. 5m <sup>2</sup>
Confined to contents $E_2$	50% of compartment (500m <sup>2</sup> )
Confined to compartment of origin $E_3$	100% of compartment (1000m <sup>2</sup> )
Spread beyond compartment of origin $E_4$	2x compartment area (2000m <sup>2</sup> )

Buildings in Europe and America have an expected lifespan of 50-70 years.



# Example of application – property protection

## Likely total and yearly loss for most probable fire outcomes

Occupancy	Value density*	Likely damage	Likely loss	Occurrence interval	Loss per year
	[EUR/m <sup>2</sup> ]	[m <sup>2</sup> ]	[EUR]	[y]	[EUR/y]
<i><b>Sprinklered</b></i>					
Industrial	300	5	1500	13	115
Office	100	5	500	23	22
Shop	200	5	1000	10	100
<i><b>Unsprinklered</b></i>					
Industrial	300	1000	300000	25	12000
Office	100	1000	100000	44	2272
Shop	200	1000	200000	18	11100

\* Fabricated values – for demonstration only



Assessed against costs  
of fire protection per year  
\*Sprinkler system 2000 Eur/year





# **Thank you for your attention!**

This work was supported by the Slovak Research and Development Agency under the contract No. APVV-0727-12.